

ELECTRICAL SAFETY UNDERTAKING

(to be submitted at least one week prior to the event)

I, s/o, the licensee/organizer/applicant of the event to be held at from to bearing application no do hereby undertake:

1. That the temporary lighting of the structure has been installed by a competent licensed electrical engineer (specify details and enclose certificate of competence)
.....
.....
.....
2. That the source of electricity supply and the sanctioned load are as follows (enclose relevant documents)
.....
.....
3. That the load connected is not more than the sanctioned load.
4. That the load per circuit, insulation test and the installation conform to the IS:1641-1961 standard.
5. That all the electrical installations have been double earthed.
6. That all electrical wiring in the structure are in PVC sheathed conductors as well as conform to FRLS norms or vulcanized rubber cables of tough rubber have been used and all joints have been made with porcelain insulated conductors. That no twisted or tapped joints have been used.
7. That no part of the electrical circuit in the structure of the pandal will be within 15 mts of any decorative elements. And no electrical wire shall hand over the sitting enclosures.

8. That sufficient arrangement has been made for emergency lighting in case of power failure.
9. That all electrical work has been carried out as per the norms prescribed by the Indian Electricity Rules, 1956.
10. That all electrical circuits and sub-circuits are controlled and protected through main switch, fuse units/circuit breakers of requisite capacity for protection against overload and short circuit.
11. That supply of electricity in the whole premise/venue shall be controlled through Earth Leakage Protection Devices (ELCBs) to disconnect supply instantly on occurrence of leakage of current of earth fault.
12. That all non current carrying metallic fittings such as light fittings, water/desert cooler and other electrical appliances/equipments shall be connected with earth.
13. That the DG sets, Main Switch Boards and Energy Meters shall be enclosed in a separate enclosure restricting public access to such places.
14. That the metallic frame/neutral point of the generating set, main switches etc shall be properly earthed. I shall ensure that the terminal plate of the Generator set shall not be exposed and live terminals shall be covered properly.
15. That I shall submit Electrical Safety Certificate issued by issued by the Electrical Safety Inspector, Labour Department, GNCT of Delhi or an Electrical Contractor duly licenced by them, before commencement of the programme/event.

I do hereby declare that the information provided above is true and correct to the best of my knowledge, information and belief.

Signature of Licensee/Organizer/Applicant.